



Lead and Copper - 90th PERCENTILE COMPLIANCE Report (For Systems Required to Collect More Than 5 Samples)

I. PWS INFORMATION: Please refer to your DEP Lead & Copper sampling plan for approved sampling locations.

Form with fields for PWS ID #: 2034010, City / Town: BOLTON, PWS Name: Nashoba Regional High School, PWS Class: COM, and Sampling Frequency: SECOND SEMI-ANNUAL SAMPLING PERIOD.

Step 1: Place lead results in ascending order (from lowest to highest value) with lowest value at # 1, in the table below. Repeat for copper results. Please report results that are ND or less than (<) the laboratory's reported detection limit (MDL) as zero. Results at or above the laboratory's detection limit (MDL) but below 0.005 mg/L for lead or 0.05 mg/L for copper shall be reported as measured or may be reported as 0.0025 mg/L for lead or 0.025 mg/L for copper.

Step 2: Multiply the total number of samples collected by 0.9 (this is your 90th percentile sample number). Round to the nearest whole number, if necessary.

Step 3: Compare the sample result at the 90th percentile sample number against the corresponding action level. If the 90th percentile value is higher than the action level, then you have an exceedance and are required to contact MassDEP as soon as possible for information on compliance actions.

Note: Do not include school results on this form unless the PWS is a school. Remember, within 30 days of receipt, you must send individual results to the persons served at each sampled location as per 310 CMR 22.06B(6)(c)1.

Table with two main sections: LEAD RESULTS (mg/L) and COPPER RESULTS (mg/L). Each section has columns for sample number, results, and action levels. Lead results range from 0 to 0.007 mg/L. Copper results range from 0.056 to 0.118 mg/L.

*Lowest Value My system was required to collect 20 lead and copper samples. My system collected: 20 lead and copper samples. Total # of samples collected: 20 x 0.9 = 18 This number is my system's 90th percentile sample #.

Circle the 90th percentile sample # for both lead and copper in the table above, and enter the results in the appropriate spaces below.

Summary table showing 90th percentile results: Lead result is 0.010 mg/L (compared to 0.015 mg/L action level), Copper result is 0.123 mg/L (compared to 1.3 mg/L action level).

II. CERTIFICATION:

Check and complete the correct statement for lead as determined by the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

- My system was at or below the lead action level. (Checked)
My system exceeded the lead action level and ... sampling sites exceeded the lead action level.

Check and complete the correct statement for copper as determined from the above results. If you have an exceedance and you are a community system you must comply with the Consumer Confidence Rule (CCR) reporting requirements in accordance with 310 CMR 22.16A(4)(i)6.

- My system was at or below the copper action level. (Checked)
My system exceeded the copper action level and ... sampling sites exceeded the copper action level.

My signature below indicates that all sampling sites on this report have been previously approved in writing by the DEP, and both the sites and sampling procedures used comply with 310 CMR 22.06B(7). I certify under penalty of law that I am the person authorized to fill out this form and the information contained herein is true, accurate and complete to the best of my knowledge and belief.

Signature and Title section for Lead Operator - Water, signed by Adam B. Bentley on December 29th 2021.